

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 108

Dated: 12/05/2026

It is certified that an inspection team headed by

Mohd. Rizwan Multani (Asst Engineer)

(Name of Officers with designation) from

PHED Lab

PHED

inspected the

Sophia School near Railway Colony

(Name & Address of the school) on

12 May 2026

(date of inspection) and on the basis of

Water Test Report (Attached) bearing no.

W/iforms

dated 27.04.26

of

Skelgarh Lab

(PHED

Lab)

certified

that

the

Sophia School near Railway Colony

(Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till

06 Months

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

12/5/26
मोहम्मद रिजवान मुल्लानी
सहायक अभियन्ता

जन स्वास्थ्य अभियांत्रिकी विभाग

वितरण उपखण्ड बडम, कोटा

To

Sophia School

near Railway Colony

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



OFFICE OF THE SENIOR CHEMIST
REGIONAL LABORATORY, PHED, KOTA, RAJASTHAN
PHED Campus, AKELGARH KOTA-324010



Test Report
(CHEMICAL & BACTERIOLOGICAL EXAMINATION OF WATER)

Desp. No. : 87

Dated : 27.04.26

Issued to:

Principal

Sophia Sr. Sec. School, New Railway Colony
Kota

District: Kota

Block/City: Kota

Sample No. Collected by Lab

Ref ID	4		Sample Code No.	PC-06 PB-06	
Reference : Letter No.		NIL	Source :	RO	
Reference Date:		20.04.26	Source Location :	New Railway Colony Kota Jn.	
Date of Receipt :		20.04.26	Habitation/Ward No. :	-	
Sample ID	6		Village/Colony/Nagar :	-	
Name of Sample Collector:		Vinod	Gram Panchayat/City Area :	-	
Designation of Sample Collector:		0	Date of Collection :	20.04.26	
Latitude of Location			Start Date of Examination :	20.04.26	
Longitude of Location			End Date of Examination :	27.04.26	
Elevation of Location					
Test Parameters		IS-10500:2012(RA 2023)		Sample Report No.	
		Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	References Method:	
1	pH At Temp. 25 ^o C	6.5 to 8.5	No relaxation	[IS 3025, P-11], 2022	8.42
2	Turbidity	1.0	5.0	-	0.46
3	Total Alkalinity (as CaCO ₃) mg/l	200	600	[IS 3025, P-23], 2023	160
4	Total Hardness (as CaCO ₃) mg/l	200	600	[IS 3025, P-21], 2009 (RA 2023)	150
5	Chloride (as Cl ⁻) mg/l	250	1000	[IS 3025, P-32],2025	30
6	Nitrates (as NO ₃ ⁻) mg/l	45	No relaxation	[APHA, Ed24, 4500-B] NO3: 2023	2
7	Fluoride (as F ⁻) mg/l	1.0	1.5	[IS 3025, P-60], 2008 (RA 2023)	1.100
8	Total Dissolved Solids (TDS) mg/l At 180 ^o C	500	2000	[IS 3025 P-16]: 2023 /APHA, Ed24, 2510-B] Cond.2023	345
9	Total Coliform (MPN/100ml)	Nil	Nil	-	NIL

(*ADL= Above detection limit; BDL= Below detection limit)

**REPORT IS NOT VALID FOR
JUDICIAL AND COMMERCIAL
PURPOSE**

Authorized Signatory

[Signature]

Senior Chemist
PHED Reg. Lab. Kota

NOTE:

- 1 This test report shall not be reproduce except in full, unless permission for the reproduction of an approved abstract has been obtained from the Senior Chemist, REGIONAL LABORATORY PHED, KOTA (Rajasthan).
- 2 This test report relates only to the samples/items submitted to the laboratory for test.
- 3 This report is not valid for legal cases/legal purposes.
- 4 Sample will be preserved only for 15 days from date of receipt.
- 5 Measurement of uncertainty and standard methods will be provided to customer on demand.

Telephone : 0744-2470946

E-mail: lab.kot.phed@rajasthan.gov.in

-----End of the Report-----